

Introduction to wind energy systems

H.-J. WAGNER(*)

*Energy Systems and Energy Economics, Ruhr-University Bochum
P.O. Box 102148, 44721 Bochum, Germany*

Summary. — This article presents the basic concepts of wind energy and deals with the physics and mechanics of operation. It describes the conversion of wind energy into rotation of turbine, and the critical parameters governing the efficiency of this conversion. After that it presents an overview of various parts and components of windmills. The connection to the electrical grid, the world status of wind energy use for electricity production, the cost situation and research and development needs are further aspects which will be considered.

1. – Different wind turbine types: An overview

Today there are various types of wind turbines in operation, (fig. 1 gives an overview). The most common device is the horizontal axis wind turbine. This turbine consists of only a few aerodynamically optimised rotor blades, which for the purpose of regulation usually can be tumbled about their long axis (Pitch-regulation). Another cheaper way to regulate it, consists in designing the blades in such a way that the air streaming along the blades will go into turbulence at a certain speed (Stall-Regulation). These turbines can deliver power ranging from 10 kW to some MW. The largest turbine on the European

(*) E-mail: lee@lee.rub.de




Fig. 1. – Overview of the different types of wind turbines.

market has a power of 3.6 MW, bigger machines are testing. The efficiency of this type of turbine is very high. Therefore, it is solely used for electricity generation which needs “high-speed engines” to keep the gear transmission and the generator small and cheap.

Another conventional (older) type of horizontal-axis rotor, is the multiblade wind turbine. It was first built about one hundred years ago. Such wind mills have a high starting torque which makes them suitable for driving mechanical water pumps. The number of rotations is low, and the blades are made from simple sheets with an easy geometry. For pumping water, a rotation regulating system is not necessary, but there is a mechanical safety system installed to protect the turbine against storm damage. By using a so-called wind-sheet in lee direction the rotor is turned in the direction of the wind. In order to increase the number of rotations, this type of turbine had been equipped with aerodynamically more efficient blades facilitating the production of electricity, here the area of a blade is smaller.

The mechanical stability of such “slow-speed turbines” is very high, some have had operation periods of more than fifty years.

A third type of turbine is known as DARRIEUS; a vertical-axis construction. Their advantage is that they do not depend on the direction of the wind. To start, they need the help of a generator working as motor or the help of a SAVONIUS rotor installed on top of the vertical axis. In the nineteen eighties a reasonable number of DARRIEUS turbines had been installed in California, but a further expansion into the higher power range and in the European markets has not taken place. One reason may be that they are noisier than horizontal-axis turbines. Another disadvantage is that wind velocity increases significantly with height, making horizontal-axis wheels on towers more economical. Nevertheless, there are some companies producing DARRIEUS turbines in the very low power range of a few kilowatts for decentralised electricity supply in areas without electrical grids, *e.g.*, in rural areas of developing countries.

The SAVONIUS rotor is only used for research activities, *e.g.* as a measurement device especially for wind velocity, it is not used for power production. Therefore it will not be discussed in detail in this paper.

The last technique to be dealt with is known as Up-Stream-Power-Station or thermal tower. In principle, it can be regarded as a mix between a wind turbine and a solar collector. In the top of a narrow, high tower is a wind wheel on a vertical axis driven by the rising warm air. A solar collector installed around the foot of the tower heats up the air. The design of the collector is simple; a transparent plastic foil is fixed over several metres on the ground in a circle around the tower. Therefore, the station needs a lot of space and the tower has to be very high. Such a system has a very poor efficiency, only about one percent. World wide there has only been one Up-Stream-Power- Station built so far, it was designed by a German company. For some years it worked satisfactorily at the location of Manzarenas in Spain, but in the mid eighties it was destroyed by bad weather. This station had an electrical power of 20 kW, the tower was about 200 m high, and the collector had a diameter of approximately the same size. A second Up-Stream-Power- Station with an electrical performance of 200 MW was discussed in Australia, but not realised. The tower height should be about 1000 m and the diameter of the collector area should be about 7000 m. No new Up-Stream-Power-Station has been designed and installed so far. Since there has been tremendous technical progress over the last ten years regarding solar farm stations as well as horizontal-axis wind turbines.

2. – Physical basics

2.1. Energy content of the wind. – The following section will be used to mathematically explain where the energy in the wind comes from and what factors it depends on.

Power is defined as

$$(2.1) \quad P = \frac{E}{t} = \frac{1}{2} \cdot A \cdot \rho_a \cdot v^3,$$

with

E : kinetic energy,

A : area,

ρ_a : specific density of the air,

v : wind velocity.

Therefore, it is also proportional to the cube of the wind speed, v^3 .

From fig. 2, it can be seen that the power output per m^2 of the rotor blade is not linearly proportional to the wind velocity, as proven in the theory above. This means that it is more profitable to place a wind turbine in a location with occasional high winds, than in a location where there is a constant low wind speed. Measurement at different places shows that the distribution of wind velocity over the year could be described by a Weibull-equitation. That means that at least about 2/3 of the produced electricity will be earned by the upper third of wind velocity.




Fig. 2. – Relationship between wind velocity and power output (yearly average valid for Germany) ([1], p. 241 ff).

From a mechanical point of view, the power density range increases by one thousand for a wind speed change of just 10 m/s, thus producing a construction limit problem. Therefore, wind turbines are constructed to harness only the power from wind speeds in the upper regions.

2.2. *Power coefficients.* – There is now the question of how much of the energy in the wind can be transferred to the blade as mechanical energy.

Betz' law and c_p

Betz' law states that you can only convert a maximum of 59% of the kinetic energy in the wind to mechanical energy using a wind turbine. This is because the wind on the back side of the rotor must have a high enough velocity to move away and allow more wind through the plane of the rotor.

The relationship between the power of the rotor blade P_R and the maximum power $P_{R\max}$ is given by the power coefficient c_p :

$$(2.2) \quad P_R = P_1 - P_2 = c_p \cdot P_{R\max}.$$

The maximum power coefficient is determined through the ratio v_2/v_1 and setting the derivation to zero.

$$(2.3) \quad c_{p\max} = \frac{16}{17} = 0.593 \quad \text{with} \quad v_2 = \frac{1}{3} \cdot v_1,$$

Therefore, an ideal turbine will slow down the wind by 2/3 of its original speed (Betz' law).

The issues discussed in the theory can be summed up and related to the design of a wind energy turbine, by the so-called Cooking recipe:

“Cooking recipe” for the design of wind turbines.

1. A high aerofoil form ratio leads to a high Tip-speed ratio and therefore, a large power coefficient c_p .

⇒ Modern turbines with a good aerodynamic profile rotate quickly.

2. Simple profiles with smaller profile form ratios have a small Tip-speed ratio. Therefore, the area of the rotor radius that is occupied by blades must be increased in order to increase the power coefficient.

⇒ Slow rotating turbines have poor aerodynamic profiles and a high number of blades.

3. The profile form ratio and the tip-speed ratio have a considerably greater influence on the power coefficient than the number of blades.

⇒ The quality of an aerofoil in respect to a high-speed turbine, has an inferior significance.

3. – Technical design of wind turbines

3.1. The design with gearbox. – The details of a design with gearbox are shown in fig. 3. The main aspect of the classic design is the split shaft system, where the main shaft turns slowly with the rotor blades and the torque is transmitted through a gearbox to the high-speed secondary shaft that drives the few-pole pair generator.

The transmission of torque to the generator is shut off by means of a large disk brake on the main shaft. A mechanical system controls the pitch of the blades, so pitch control can also be used to stop the operation of the turbine in *e.g.* storm conditions. The pitch mechanism is driven by a hydraulic system, with oil as the popular medium. This system needs almost yearly maintenance and constant pressure monitoring, along with the gear box which is lubricated with oil. For constructions without a main brake, each blade has its pitch angle controlled by a small electric motor.

To reduce weight generators with permanent magnets were developed. Some producers are equipping their converters as testing converters.

Wind speed and direction measuring apparatuses are located at the back of the hub head. A rack-and-pinion mechanism at the join of the hub and the tower, allows the hub to be rotated in to the wind direction, and out of it in storm conditions.

3.2. The design without gearbox. – Some companies, *e.g.* the German company Enercon, design another turbine type, without gearbox. The scheme of such a turbine is shown in fig. 4, where the main design aspects can be clearly seen.




Fig. 3. – The design with gearbox.




Fig. 4. – The design without gearbox (Enercon E-66).

This design has just one stationary shaft. The rotor blades and the generator are both mounted on this shaft. The generator is in the form of a large spoked wheel with *e.g.* forty-two pole pairs, around the outer circumference and stators mounted on a stationary arm around the wheel. The wheel is fixed to the blade apparatus, so it rotates slowly with the blades. Therefore, there is no need for a gearbox, rotating shafts or a disk brake. This minimising of mechanical parts simplifies the maintenance and production of the turbine.

The whole system is automated; pitch control and hub direction are controlled by a central computer, which operates the small directional motors.

3.3. Aspects of design and development. – There are several critical aspects of a wind turbine that need to be considered in the design phase, to ensure the turbine will be economic and durable.

The tower

In principle, the tower needs to be as tall as possible, because the wind speed increases with height. However, the height is limited by costing issues; an increase in tower height of 10 m costs an extra fifteen thousand dollars, and a tower height of over 100 m requires an aircraft-warning beacon, which is again so expensive.

Heat energy

Large turbines (> 1 MW), have an average generator efficiency of 98%. Heat is also generated in the mechanical parts of the machine including the bearings and the gear box. This means that around 40 kW of power are lost to the generator heating up during operation. This heat energy needs to be controlled to prevent damage to the machine parts. A large fan system is mounted in on the back side of the hub of a turbine and used to draw cool air through the hub and remove the heat energy emitted during operation.

Control and Monitoring

The following aspects of a wind turbine need to be controlled and monitored to ensure effective operation of a wind turbine within the legal limits:

- by large turbines; vibration levels,
- speed of rotation and the pitch angle of the rotor blades,
- the natural wind speed and direction,
- the voltage and frequency of the electricity produced,
- the output phase angle compared to the grid phase angle,
- the consistency of the electrical power output,
- the acquisition and storage of electrical signals,

- signal conversion equipment for the directional motors,
- rotational speed at night, to reduce the noise levels, because the noise is proportional to the blade-tip speed to the power six.

Mechanical stability

The following forces affect the stability of the mechanical system:

- gravity,
- centrifugal forces on the rotor blades,
- pressure changes on the blade due to the shadow effect the tower creates,
- stochastic power output of the turbine due to wind energy levels continually changing,
- resonance of the blades.

Wind direction set-up

A wind turbine can be designed to face in to the wind (windward), or away from it (leeward). A leeward turbine has the advantage of being self-orientating, but the disadvantage of the tower disturbing the wind velocity profile, before the wind has reached the plane of the rotor blades. The pressure and speed differences experienced by the blade as it passes the tower, result in stresses on the hub, which need to be alleviated by use of an extra mechanism in the hub to allow the rotor blades to move out of their usual plane of rotation.

TABLE I. – *The technical figures of two different multi-megawatt wind turbines for onshore.*

	Enercon E-182 E3	REpower 3.2 MW
Design	without gearbox	with gearbox
Hub height	80–130 m (onshore)	100–130 m (onshore)
No. of blades	3	3
Rotor speed	6–18 rpm	6.7–12 rpm
Rotor diameter	82 m	114 m
Material of blade	Fibreglass (reinforced epoxy)	Fibreglass (reinforced epoxy)
Blade regulation	Pitch	Pitch
Rated power	3 MW	3.2 MW
Transmission ratio of gearbox	None	approx. 99
Generator	Multipole	Asynchronous, few poles
Grid connection	Via frequency converters	Via frequency converters

3.4. Technical figures of two modern wind turbines. – The largest market introduced machine up to the year 2012, is a 7.5 MW turbine from the company Enercon.

Table I gives an idea of the technical data of wind turbines of the 3 MW class. A design with and without gearbox have been chosen to show the different operation of their generators.

4. – Connection to the electrical grid

The main electrical grid has a constant frequency, *e.g.* of 50 Hz or 60 Hz, and a constant phase angle. Therefore, a wind turbine must produce electricity with the same constant values in order to be integrated into the main grid.

The input energy of a wind turbine is proportional to the wind speed, but the wind speed is never constant. Each wind speed has a corresponding rotor rotation speed, at which the maximum power is produced. This maximum occurs for different wind speeds at different rates of rotation. However, the rate of rotation must be held constant in order to achieve the required constant output frequency or the wind turbine has to be connected to the grid by doubly fed asynchronous generator or by electronic frequency converters.

A small turbine can be connected directly into the grid network at 0.4 kV. When the wind turbine is integrated into the grid network, there must be no voltage change, voltage oscillation or flicker experienced in the homes on that network branch. The loss of voltage due to resistance in the cabling can be avoided by increasing the diameter of the cables. It is often required that a new network branch is constructed and linked to the transformer, in order to reduce the voltage disturbances. This increases the installation costs of the turbine.

Megawatt turbines cannot be connected to the grid at the 0.4 kV stage, but have to be connected in at 10–30 kV, which is the usual level of the city electricity share distribution. In remote areas, where a 30 kV connection is not established, the connection must be created and financed by the wind park developers. Wind parks with a lot of Megawatt turbines can also be connected into the electrical grid, *e.g.* at the 110 kV level in Germany.


As mentioned earlier the maximum power output is obtained only in few hours during the year. Figure 5 shows a typical load distribution, measured in Germany.

With larger wind energy installations in future this uneven distribution leads to the need of higher regulation capacities by conventional power systems.

Grid connection of offshore wind farms poses a technical and economical challenge to wind turbine and grid operators. In the initial phase, the still quite limited capacity of early pilot farms enables using a conventional three-phase AC connection to the onshore grid system which is a well-known technology and inexpensive. This wind farms were also located near to the coast, the energy losses by using AC was therefore limited.

Greater capacities and remote offshore sites make it technically difficult to connect offshore wind farms to the mainland grid by using AC undersea cables. Losses, reactive power production and limited capacity of the sea cables may become important in the

Percent of total capacity (28 MW)



Percent of total capacity (28 MW)




Fig. 5. – Load distribution measurement (Germany).

future. High-voltage direct current transmission to land could be a solution but it is technically more complicated and more expensive.

At the moment there are some plans for connecting offshore wind farms to the main-land grid. Some lines, AC and DC operated, are already into operation, some more are under realising ore planning. To protect environment on sea several wind farms are connected to one line.

To connect the offshore wind farm to the onshore grid an internal grid is necessary. The produced power has to be fed to an offshore transformer substation. Wind turbines are connected to it via undersea cables by a voltage of about 30 kV. After stepping-up to the transmission line voltage, the power is conveyed to shore.

5. – Use of wind energy

5.1. *World-wide status.* – In the nineteen eighties, it was the USA that took the lead in establishing wind farms. They set over 10000 turbines into operation, each generating between 80–200 kW. In Europe it was Denmark that was the main pioneers of wind energy. At the end of the twenty-first century, Germany has taken the world lead, producing about a third of the world's wind produced electricity until 2008.

Many governments have began to produce initiative schemes to increase the economic feasibility of wind turbines. Some initiatives used include, paying more for wind produced electricity, and providing a proportion of the initial construction costs. Governments of industrial countries, or those with a high power consumption, are eager to promote wind

TABLE II. – *World wind power production* [2].

Land/Region	Total installed rated power up to the end of 2011 [GW]
China	63
USA	47
Germany	29
Spain	22
India	16
Italy	7
France	7
UK	7
Canada	5
Portugal	4
Remaining countries	32
Total	239

energy, because it is environmentally clean and sustainable and limits the need for fossil fuel usage (table II).

The world total is about 239000 MW. This is about 1% of the worldwide installed capacity of power stations (water, coal, naturalgas, nuclear).

5.2. Investment and operation costs. – The costs involved in installing a wind turbine vary depending on the design, size and chosen location of the new turbine. The infrastructure costs can be minimised by constructing wind parks, where a number of new turbines are installed on the same sight. An example of the investment costs for a wind park at land in Germany is shown in table III.

The money invested in an average wind park on land depreciates over about a ten year period. During this period, the set-up and installation costs are high, along with the loan repayments and insurance costs. After this period, the costs then decrease. Over the next ten years, a financial return can then be made on the investment, when the price for the electricity per kilowatt hour is set at a high value by the government. This means it is economic to ensure the durability of the installed turbines, so maintenance costs after the ten year period are kept low and the investors can receive a good return on their investment.

The above example of investment costs for wind parks on land in Germany is non-transferable to other countries. Especially the employee's wages and the structure of financing wind farms are quite different. Nevertheless power generating by wind turbines in developed countries with existing electrical grid and sufficient installed power, costs three to four times in comparison to power generation by conventional power stations.

TABLE III. – *The investment costs of Amesdorf and Wellen wind park in Germany, (status: Nov. 2001).*

	Invested costs (Million Euros)	Percent of total
Wind Park (ten 1.5 MW turbines) incl. transport, assembly, cabling, starting-up, grid connection and reinforcement, infrastructure.	15.8	83%
Technical planning, foundation soil analysis, survey, and grid connection fee.	2.0	10%
Commission, funding during phase of construction, interest risk.	0.1	1%
Compensatory measures during phase of construction.	0.3	1.3%
Raising of capital.	0.5	3%
Financial, contractual and fiscal consulting.	0.3	1.3%
Grand total	19	100%

Wind parks on sea need higher specific investments, although the wind offer is better on sea than on land. The costs of produced electricity are higher by an offshore wind park (status 2012). The expectation is that the cost could be reducing for new offshore wind parks in next years. A lot of countries are supporting the installation of wind converters by supporting programs.

5.3. Environmental aspects. – Wind energy is a renewable energy source; therefore it holds many advantages over the fossil fuels, which have diminishing reserves. Wind energy is clean in regard to toxic emissions. Therefore, it does not add to Global warming or Acid rain problems.

The wind turbines can affect the environment in aesthetic and human intrusive ways. This is because they must be sited in prominent locations and through the nature the rotation of their blades; they produce optical distortions *i.e.* flickering shadows, and a humming noise. The land required for the sighting of a wind park can be considered large, if all the access routes are also taken into consideration. However, they very rarely require the resettlement of communities, which is a problem associated with, *e.g.*, large Hydro-Electric-Power stations. The danger to birds of the rotating blades has been questioned, but it has been found that the birds change their flight paths to avoid the blades. It has also be questioned whether the reduced wind speed at ground level, affects the growth of flora. This is answered by the observation that many wind parks have animals grazing between the turbines.

6. – Research and development needs

The field of wind converter is connected with high technical development activities since a lot of years. According to the first report of the project “Wind Energy Thematic Network” founded by the European Commission, some aspects of the R&D needs are described below (facts are taken from [3]), which are also relevant in the year 2012:

1. *Environmental & Social Impacts* (e.g. enhancing local incentives by developing participation models)
 - Methods to integrate wind turbines visually in to the landscape
 - Reduction of noise impacts
 - Mitigating impacts on bird populations, habitats and flight paths
 - Turbine design regarding life cycle analysis
 - Analyse social effects like local employment, investment, taxes etc.
2. *Wind Turbine & Component Design Issues* (e.g. basic research in aerodynamics, structural dynamics, structural design and control)
 - New materials with higher strength like carbon fibre for the blades
 - Feasibility studies of new wind turbines concepts and innovations
 - Integration of demand site requirements in the design of turbine, e.g. electrical control system interaction with grid requirement
3. *Testing, Standardisation, & Certification* (e.g. common accepted certification procedures for wind turbines and wind farms)
 - Identification of standards lacking, and initiation of appropriate actions for new standards
 - Standards for service and maintenance concepts of offshore wind converters
4. *Grid Integration, Energy Systems & Resource Prediction* (e.g. forecast of wind resource)
 - Development of scenarios for redesigning the grid system with high wind penetration
 - Increasing both: power quality and consistency
 - Energy management and storage systems for stand alone applications
5. *Operation & Maintenance* (e.g. advanced condition monitoring)
 - Development of early failure detection and condition systems
 - Development in preventative maintenance
 - Standardisation of components for easy replacement

- Certification of service and maintenance concepts
 - Cold and icing climates resource assessment
6. *Offshore Wind Technology* (e.g. research into the control and efficiency of very large wind farms and more cost effective foundations, transport and installation techniques)
- Monitoring of environmental impacts (effects on birds, effects of noise and vibration on marine life especially by installation of wind converter etc.)
 - Development of deep water foundation structures (fundamental wind turbine design research)
 - offshore meteorology
 - Special designs of systems and components for transportation, erection, access and maintenance of offshore wind turbines
 - investigate the use of energy storage
 - Improve corrosion protecting systems regarding the offshore conditions

In addition to these aspects there have been done a lot of R&D needs by operating and market introduced wind turbines, e.g.:

- better state of knowledge of the dynamic forces on the drive train,
- improvement of the availability of gear boxes,
- optimisation of control units and control systems,
- development of central lubrication systems.

7. – Outlook

The wind energy market has grown because of the environmental advantages of harnessing a clean and unexhaustable energy source and because of the economic incentives supplied by several governments. However, energy is required from other generation methods during the building phase of a new turbine, so in this period, Greenhouse gases and air pollution will be added to. If the life cycle of a wind turbine is looked at, more pollutants are saved on during operation, than are emitted during the building phase.

A wind turbine is not a self-sustainable power station. This means that back-up power generation is needed at the times when the turbine is unoperational. This back-up is nowadays supplied by the established fossil fuel power stations. If the number of wind turbines increases, the need for extra investment in the back-up generation systems will arise, in order to maintain a stable electricity grid system. The challenges in this case are that existing power stations will deliver less electricity than before. Under this condition the electricity generation prices for new power stations are increasing due to smaller load duration time than before.

For more information especially in respects to technological and ecological aspects (life time aspects) see [4].

These additional investments will need in some cases subsidies.

However, wind energy is still one of the most important renewable energy resources for the future, because it can be harnessed in a clean and unexhaustable manner, through the application of technically advanced and efficient machinery.

REFERENCES

- [1] KLEEMANN M. and MELIB M., *Regenerative Energiequellen*, 2.Auflage (Springer-Verlag, Heidelberg) 1993.
- [2] ENDER C., DEWI Magazin, N. 40, Febr. 2012, pp. 30-43, ISSN 0946-1787.
- [3] EWEA, The European Wind Industry: Strategic Plan For Research & Development, First Report, Creating the knowledge foundation for a clean energy era.
- [4] WAGNER H.-J. and MATHUR J., *Introduction to Wind Energy Systems – Basics, Technology and Operation* (Springer-Verlag, Berlin) 2009, ISBN 978-3-642-02023-0.