Visual Simultaneous Localization And Mapping (VSLAM) methods applied to indoor 3D topographical and radiological mapping in real-time

Felix Hautot^{1,3}, Philippe Dubart², Charles-Olivier Bacri³, Benjamin Chagneau², Roger Abou-Khalil⁴

¹AREVA D&S, Technical Department, 1 route de la Noue 91196 Gif-sur-Yvette, France

²AREVA D&S Technical Department, Marcoule, France

³CSNSM (IN2P3/CNRS), Bat 104 et 108, 91405 Orsay, France

⁴AREVA Corporate, Innovation Department, 1 place Jean Millier, 92084 Paris La Défense, France

Abstract. New developments in the field of robotics and computer vision enables to merge sensors to allow fast real-time localization of radiological measurements in the space/volume with near-real time radioactive sources identification and characterization. These capabilities lead nuclear investigations to a more efficient way for operators' dosimetry evaluation, intervention *scenarii* and risks mitigation and simulations, such as accidents in unknown potentially contaminated areas or during dismantling operations

1 Introduction

Nuclear back-end activities such as decontamination and dismantling lead stakeholders to develop new methods in order to decrease operators dose rate integration and increase the efficiency of waste management. One of the current fields of investigations concerns exploration of potentially contaminated premises. These explorations are preliminary to any kind of operation; they must be precise, exhaustive and reliable, especially concerning radioactivity localization in volume.

Furthermore, after Fukushima nuclear accident, and due to lack of efficient indoor investigations solutions, operators were conducted to find new methods of investigations in order to evaluate the dispersion of radionuclides in destroyed zones, especially for outdoor areas, using Global Positioning Systems (GPS) and Geographical Information Systems (GIS) as described in [1]. In both cases, nuclear dismantling and accidents situations, the first aim is to explore unknown potentially contaminated areas and premises so as to locate radioactive sources. Previous methods needed Geographical Information systems and Global positioning systems or placement of markers inside the building before localization of measurements, but plans and maps are often out-dated or unavailable.

Since the end of 2000's years, new emergent technologies in the field of video games and robotics enable to consider fast computations due to new embedded GPU and CPU architectures. Since the Microsoft KinectTM has been released in 2010, a lot of developers "hacked" the 3D camera system in order to use 3D video streams in many fields of use such as robotics, motion capture or 3D imaging processing

algorithms development. During the few following years, Light and low power consuming 3D cameras enabled to consider new 3D reconstruction of environment methods such as Simultaneous Localization And Mapping (SLAM) based on visual odometry [2].

This paper will present new progresses in merging SLAM and nuclear measurement in motion methods in order to detect, locate, and evaluate the activity of radioactive sources in 3D.

These new methods enable to reconstruct indoor areas and eventually out-door areas in real-time and 3D and also reconstruct 3D radioactive sources in volume.

In 2013, AREVA D&S started an R&D program for developing new investigations technics based on autonomous sensing robotics and localization apparatus in order to provide new efficient exploration and characterization methods of contaminated premises and areas. This work corresponds to MANUELATM system developments by Areva D&S. Part of this work is protected by a patent (number WO2015024694) [3].

2 Material and Methods

2.1 General method

The presented method is based on two completely different technics. The first one, which is called SLAM, is well known in the field of robotics, it constitutes a specific branch of computer perception R&D. The second one, as described in [4], concerns radioactive sources localization and activity quantification from *in-situ* measurements and data acquisitions. The usual method for these acquisition are time consuming for operators and, in consequence, integrated dose of workers during these investigation could be decreased.

* Corresponding author: hautot@csnsm.in2p3.fr

Chen *et al.* [5] described such a mapping system based on merging RGBD-camera with radioactive sensors. The presented system automatically detects radioactive sources by estimating their intensities during acquisition with a deported computer. Our aim was to build a complete autonomous system for being totally independent of any external structures, including GPS.

A great problem for an autonomous apparatus (such as robot) is to locate itself in unknown environments, in order to compute appropriate motions and trajectories in volume. A simple formulation of this problem is that the apparatus must know its position in a map in order to estimate its trajectory. Using sensors, the system will build a map and compute its next position (translation and orientation in volume) at each acquisition step.

In order to compute SLAM inherent calculation in autonomous and light device development context, hardware specifications investigations are particularly important, due to required software performances.

2.2 Hardware

The presented radiological mapping system is embedded and designed for real-time investigations inside contaminated areas or premises. The whole system is enclosed and autonomous, and needs no external marker or network for being active. However, the operator's real-time intervention requires real-time reconstruction and visualization, which is very performance-consuming.

2.2.1 Sensors

The system software input uses different sensors:

- 3D camera based on active stereoscopy. As shown in figure 1, this camera's output consists in two different kinds of frame, a normal colour pixels image, and a depth map. The depth map is based on active stereoscopy technique and provides each colour pixel distance to sensor.

Figure 1: Outcoming data from 3D sensor (left: depth-map, right: RGB image)

- Nuclear measurements sensors including a dose rate meter and a micro CZT spectrometer (Figure 2)

Figure 2: Outcoming data from nuclear measurements sensors

2.2.2 Computing unit

The 3D reconstruction and nuclear measurements are performed fully embedded, in real-time, due to operator interactions and acquisition time optimization in contaminated environment. Furthermore, the computing hardware must be fan-less in order to avoid nuclear contamination. So as to satisfy these constraints, the embedded CPU must be enough powerful for supporting parallel processing.

2.3 Simultaneous localization And Mapping

SLAM concept (simultaneous localization and mapping) can be performed by merging different kind of sensors, such as Inertial Measurement Units (IMU), accelerometers, sonars, lidars, cameras for example. In our method, only 3D cameras are used. We propose to merge two different kinds of algorithms so as to reconstruct the environment in 3D, compute the trajectory with 6 degrees of freedom (translation, pitch, roll, and yaw) in volume, and merge measurements with the device's poses.

Two problems appear during that kind of acquisition. First of all, slight error during the odometry computation causes a non-regular drift of the trajectory. The second problem concerns the memory management of acquisitions in real time. Indeed, 3D video gross data can quickly cost a considerable amount of active memory during the acquisition. Then, implementing a circular buffer is necessary for increasing the scanning volume up to hundreds of cube meters.

In order to develop our measurement method, we modified the RtabMap software [6-7-8] provided by IntroLab (Sherbrooke). By this way, we are able to use visual odometry with 3D cameras in order to reconstruct the environment and compute the device trajectory at 25Hz.

Pose-graph visual Slam is based on the principle that each acquisition step is a combination of constraints links between observations. These constraints are established using features detection and extractions of each processed image. This kind of SLAM problem is represented with graphs of constraints. Each observation of the robot creates node, new links and constraints. This method allows fast node recognition and including loop & closure based-on optimization methods.

2.3.1 Visual Odometry

The goal of visual odometry is to detect the relative motion between two poses of the camera, and then to back-project the 3D and RGB streams in a computing reconstruction volume. This problem can be exposed as equation 1. This equation describes the transformation of each pixel of the camera to a 3D point, depending on intrinsic and extrinsic camera parameters (Equation 1).

$$z \begin{pmatrix} u \\ v \\ 1 \end{pmatrix} = \begin{pmatrix} f_x & 0 & c_x & 0 \\ 0 & f_y & c_y & 0 \\ 0 & 0 & 1 & 0 \end{pmatrix} \begin{pmatrix} R_{1,1} & R_{1,2} & R_{1,3} & T_1 \\ R_{2,1} & R_{2,2} & R_{2,3} & T_2 \\ R_{3,1} & R_{3,2} & R_{3,3} & T_3 \\ 0 & 0 & 0 & 1 \end{pmatrix} \begin{pmatrix} x \\ y \\ z \\ 1 \end{pmatrix} \quad [1]$$

pixel
Camera intrinsic parameters
Camera extrinsic parameters
3D point

z : depth at pixel (u,v)

u, v : coordinates of the considered pixel

f_x : focal length along x

f_y : focal length along y

c_x, c_y : lens centering on the optical axis

$R_{a,b}$: element of the rotation matrix

T_a : element of the translation vector

x, y, z : projected point coordinates in volume.

Visual odometry is processed on a real-time RGB data stream to detect the motions of the device in volume and get the colour for reconstruction. Simultaneously, the corresponding depth stream is used for calculating the rotation/translation matrix between two successive frames.

Figure 3: Visual odometry processing

Visual odometry is features extraction based-on. Each RGB image is processed in order to extract interest points. These interest points are formed by image corners.

The corresponding pixel in the depth map is also extracted.

Depending on the pine-hole model, features are then back-projected in volume.

As described in figure 3, unique correspondences are researched between two sets of consecutive images. If enough unique correspondences are detected, then, odometry is processed. A RANdom SAMple Consensus (RANSAC) algorithm calculates the best spatial transformation between input images (rotation and translation).

2.3.2 Loop and closure

Errors during the pose matrix computation cause a non-regular drift of the trajectory. Graph-Slam and constrained optimization methods based on loop-and-closure correct this drift when a previously scanned zone is reached by adding constraints to previous acquired constraint graph as described in figure 4 [6].

Figure 4: Loop and closure optimization

2.4 Nuclear measurement Management and location

Measurements in motion related work [9] by F. Panza, describes a system used within motions in two dimensions with collimated measurements probes. In this case, using leads collimator could be possible, but our case concerns a handheld system measuring in a near 4pi sphere, and moving with six degrees of freedom.

All the data (nuclear measurement and positioning, 3D geographical and trajectory reconstruction) are performed in real-time while the device can have different kinds of status: moving or motionless. All the nuclear measurements are considered isotropic.

Each set of measurement (integrated or not) is attached to the graph-slam geographical constraints structure. This allows performing trajectory optimizations and measurement positioning optimization simultaneously.

In order to satisfy the “real-time” constraint, a user interface displays every current measurement and process step in real-time in order to provide all pertinent and essential information to the operator (figure 5).

Figure 5: Acquisition interface

2.4.1 Continuous measurement

Dose rate measurements are processed during the 3D reconstruction with a lower frequency (around 2Hz) than video processing (around 20-25Hz). In order to manage the nuclear measurement positioning, we had to find a compromise between positioning uncertainty, which depends on the counting time and counting uncertainty that depends on the inverse counting time. So, first and foremost, dose rate measurement is positioned at half path distance during integration (Figure 6).

Figure 6: Nuclear measurements positioning

Gamma spectrometry measurements are processed with an even lower frequency (around 0.3-0.5Hz) than the dose rate measurements. Consequently, the uncertainty on spectrum positioning is more important, compared to dose rate positioning. So as to compensate this error, dose rate values will help to distribute weighted spectrums for the acquired one (Figure 7).

Figure 7: Spectrum positioning management

2.4.2 Integrating measurement

In some case, very precise measurements are required to build a representative map of the environment. The fast

pose calculation method we use allows considering the device as a 3D accelerometer with a higher frequency than nuclear measurements. While the 3D video stream is being acquired, the acceleration of the device is estimated and if the device is motionless, measurements can be integrated at the current pose (Figure 8)

Figure 8: radioactive measurements positioning

2.5 Near real-time post-processing, sources localization

At the end of acquisition, radioactive source localization computation methods are available with a set of algorithms that provide interpolations and back-projections of measured radioactive data in volume. The algorithms are optimized for providing results in a few seconds, even if uncertainties could be reduced by more accurate methods.

2.5.1 Measurements 3D interpolation

For interpolating measurements in 3D, we use a simple deterministic Inverse Distance Weighting (IDW) method, which is accurate enough considering the usual radioprotection operating accuracy. Furthermore, this fast computed method allows operators to consider the operating room state of contamination very quickly with this embedded method. The used IDW method is described within equation 2 and 3.

$$v(x) = \frac{\sum_{i=0}^n w_i(x) \cdot v_i}{\sum_{i=0}^n w_i(x)} \quad [2]$$

with:

$$w_i(x) = \frac{1}{D_{x,x_i}^p} \quad [3]$$

$v(x)$: interpolated value at x

w_i : weight of the measurement point i

D_{x,x_i}^p : distance between current interpolated point and measurement point i .

n : number of measured points

2.5.2 Dose rate back projection

Back projection method is also deterministic and uses the 3D reconstruction to compute radiation emission zones in volume. This method is described within equations 4 and 5.

$$B(x) = \frac{\sum_{i=0}^n \frac{e^{-\mu_a D_{x,x_i}}}{D_{x,x_i}^2}}{n} \cdot w(x) \quad [4]$$

$$w(x) = f(\text{var}(B(x))) \quad [5]$$

n : Number of nuclear measurement point.
 $B(x)$: Back projection value (mGy.h^{-1})
 x : Location (x_1, y_1, z_1) of back-projected value
 X : Location (x_2, y_2, z_2) of nuclear measurement point
 μ_a : Linear attenuation coefficient of air (cm^{-2})
 $w(x)$: Weight associated to x location.
 $D_{X,x}$: Distance between X and x location

The back-projection algorithm inputs are:

- 3D reconstruction decimated point cloud
- Nuclear measurements and position data.

Each point of the 3D point cloud (x in eq.4) is considered as a possible radioactive source, then, emerging mean fluency or dose rate at the 3D reconstruction point ($B(x)$ in eq.4) is computed for every measured point (X in eq.4). Then, variance distribution of the back projected value enables to evaluate the possibility of radioactive source presence in volume at the back projected point.

2.5.3 Topographical study

Topographical measurements can be performed as soon as the acquisition is terminated. This function gives instant information on the situation of premises.

2.6 Offline post-processing

The device output data can be processed in back office with a set of tools for estimating accurate gamma-emitting sources localization and quantification in volume. It also provides tools for estimating effects of a dismantling or decommissioning operation on dose rate distribution and allows the user to estimate the exposure of operators during interventions.

Next subparagraphs will present these different tools such as radioactive sources quantification, operators' avatars, and topographic studies.

2.6.1 Topographical measurements

The dedicated post-processing software provides two kinds of topographical study tools, according to figure 9: a global grid containing the scanned volume for global intervention prevision and a drag and drop tool for specific structure measurements (volumes, length, and thickness).

Figure 9: topographical study interface presenting dimensioning tools.

2.6.2 3D Nuclear Measurements interpolation

Nuclear measurement interpolation characterization tool (Figure 10) is based on IDW, and uses the same principle than the near real time post-processing

interpolation method, however, slight modifications of scales allows user to refine the computation and then locate low emitting sources. Moreover, spectrometry can be exploited by interpolating user's defined region of interest of the spectrum. This enables specific studies concerning radionuclides diffusion in the investigated area, such as ^{137}Cs or ^{60}Co containers localization for example.

Figure 10: Radioactive measurements 3D interpolation

2.6.3 3D Back-projection and avatar dose integration simulation

Figure 11: Radioactive measurements 3D back-projection

Back-projection algorithm also benefits of an improved interface in order to locate accurately radionuclides in volume using spectrometry (Figure 11).

Avatars of operators can be used for estimating previsions of their exposure before operations. This dose rate integration estimation is performed by extrapolating dose rates from measurements points.

2.6.4 Sources activities estimations

Radioactive sources activities are estimated with a set of algorithms combining 3D transfer functions calculations and minimization methods (Figure 12).

Figure 12 : Radioactive sources activities estimation

- Transfer function calculation

The transfer function will quantify the relation between volume radioactive source activities and resulting dose rate for a specific radionuclide.

The first step of radioactive sources estimation consists in modelling them according to available data provided by the results of acquisition on a hand, and by operating documents on the other hand (volume, enclosure type, shielding, materials, radionuclides) (Figure 13).

Figure 13: Radioactive sources scene modeling

In order to satisfy the nearest real-time calculation constraint, the transfer function calculation method is deterministic and based on ray-tracing and radioactive kernels point distribution in volume. Potential radioactive sources are designed by the user with the help of localization algorithm.

Equation [6] describes the transfer function calculation method.

$$\dot{D}_{Bu} = \frac{A_v}{4\pi} \cdot C \iiint_V \prod_{i=0}^n \frac{Bu_i e^{-\mu_i d_i}}{d_i^2} \cdot dV \quad [6]$$

n : Number of attenuating volumes on the ray path

$\dot{D}_{Bu}$: Dose Rate at Measurement point (considering the Build-up factor)

A_v : Volume activity of the radioactive source.

C : Dose Rate – gamma fluency conversion coefficient

Bu : Build-up factor for the “i” attenuating volume

μ_i : Linear attenuation coefficient of the « i » attenuating volume

d_i : Path length in the « i » attenuating volume.

The numerical integration method for source kernels distribution in the source is a Gauss-Legendre integration based-on method.

- Radioactive sources activities minimization method.

The minimization method is based on iterative technique for which each step consists in considering a different combination of radioactive sources.

The equation system resolution method is based on the most important transfer function selection at each step of calculation.

The following figure (figure 14) presents the whole algorithm process for computing sources activities.

Figure 14: Minimization method algorithm

3. Benchmarks

Since June 2016, a set of benchmarks is performed in order to compare the performances of this acquisition system with different systems that can be considered as references. Different parts of the system are compared such as:

- 3D volumetric reconstruction
- 3D trajectory reconstruction
- Dose Rate measurements
- Spectrometry measurements
- 3D nuclear measurements interpolation
- 3D radioactive source localization without collimator.

3.1 3D volumetric reconstructions

This part of the benchmark has been realized with a 3D scanner and is based on point cloud registration techniques such as Iterative Closest Points (ICP) method. We used “Cloud compare”, developed by Telecom ParisTech and EDF R&D department.

The reference point cloud was acquired with a 3D laser scanner from Faro Corporation (Table 1).

Table 1: Comparison data

Device	Faro laser scanner	MANUELA Device
Error	6mm/10meters	?
Acquisition time	~11mn	~3mn
Dynamic/ static	Static	Dynamic
Number of vertex	2.157E+3	1.470E+3

3.1.1 Benchmark example

As an experimental test, we used a storage room “as it is” (Figure 15)

Figure 15: Benchmark situation

Room dimensions: 25 square meters, 2.5 meters high.

3.1.2 Results:

Following clouds superposition prepositioning, the ICP registration algorithm is performed in order to compute the best cloud-to-cloud matching. Then, point-to-point distance is computed for the whole reference point cloud.

Figures 16 to 18 show a part of the benchmark procedure.

The first step in figure 16 concerns Faro and MANUELA point clouds superposition in order to prepare the matching process.

Figure 16: Faro (blue) / MANUELA (RGB) point cloud superposition and registration

The second step consists in using ICP matching, and then computing point-to-point distances in the best matching case. In figure 17, the colour scale displays the distribution of point-to-point distances between point clouds, and the chart shows the distribution of these distances in the whole scene.

Figure 17: Cloud-to-cloud distance computation

The last graph displays the point-to-point distances distributions as a Gaussian (Figure 18 shows the chart of figure 17 with a different binning).

Figure 18: Cloud distance diagram

General conclusion of 3D point cloud reconstruction Benchmark shows a Gaussian distribution of cloud-to-cloud distance. Global cloud-to-cloud mean distance is around $7.3 \times 10^{-2} \text{m}$ ($\sigma = 10.2 \times 10^{-2} \text{m}$).

4 Uncertainties estimation

4.1 General considerations

Current work is going on estimating uncertainties on each step of the acquisition.

Uncertainties estimation and propagation in such kind of acquisition and processing system is necessary for interpreting the results, estimating the relative probability of presence of radioactive sources, and building sensibility analysis in order to increase the system performance, by detecting the most uncertainty generator step in the process.

The whole process chain depends on four simple entries, the RGB image, the depth map, the dose rate measurements and the spectra measurements. Each one of these entry elements is tainted by systematic and stochastic uncertainties. Moreover, each step of process generates uncertainties and amplifies the input uncertainties.

In this paragraph, we will describe all parts of the acquisition process and present the current results on a new method we use for propagating uncertainties in real-time. We compared this new method to a Monte-Carlo calculation that will be considered as the reference.

In the case of input detectors, we will only consider the model generated or counting (nuclear) measurement uncertainties.

4.1.1 Uncertainty estimation, general description

The acquisition and processing devices is decomposable in a few building blocks (sensor or processing technic). They will be considered separately in order to quantify each block uncertainty (Figure 19).

Each block will be considered as a linear system such as described in equation [7-8].

$$O = T \cdot I \quad [7]$$

$$\begin{pmatrix} u \\ v \\ w \end{pmatrix} = \begin{pmatrix} a_{1,1} & a_{1,2} & a_{1,3} \\ a_{2,1} & a_{2,2} & a_{2,3} \\ a_{3,1} & a_{3,2} & a_{3,3} \end{pmatrix} \begin{pmatrix} x \\ y \\ z \end{pmatrix} \quad [8]$$

$O(u, v, w)$: Output vector

$T(a_{x,x}, \dots, a_{x,x})$: Transformation matrix

$I(x, y, z)$: Input vector

Each of these blocks generates an intrinsic uncertainty and amplifies inputs errors. Then, the final $\|dO\|$ will represent the global uncertainty on the acquisition and processing chain.

Each system uncertainty is considered as:

- $\|dO\| = f(\|dT\|)$ error intrinsic generation estimation (Equation 9)

$$\begin{pmatrix} u + du \\ v + dv \\ w + dw \end{pmatrix} = \begin{pmatrix} a_{1,1} + da_{1,1} & a_{1,2} + da_{1,2} & a_{1,3} + da_{1,3} \\ a_{2,1} + da_{2,1} & a_{2,2} + da_{2,2} & a_{2,3} + da_{2,3} \\ a_{3,1} + da_{3,1} & a_{3,2} + da_{3,2} & a_{3,3} + da_{3,3} \end{pmatrix} \begin{pmatrix} y \\ y \\ z \end{pmatrix} \quad [9]$$

- $\|dO\| = f(\|dI\|)$ error amplification estimation (Equation 10)

$$\begin{pmatrix} u + du \\ v + dv \\ w + dw \end{pmatrix} = \begin{pmatrix} a_{1,1} & a_{1,2} & a_{1,3} \\ a_{2,1} & a_{2,2} & a_{2,3} \\ a_{3,1} & a_{3,2} & a_{3,3} \end{pmatrix} \begin{pmatrix} x + dx \\ y + dy \\ z + dz \end{pmatrix} \quad [10]$$

Figure 19: uncertainties propagation principle

We use Frobenius matrix norm (Equation 11-12) in order to quantify the global variation of matrix terms.

$$A = \begin{pmatrix} a_{0,0} & \cdots & a_{0,m} \\ \vdots & \ddots & \vdots \\ a_{n,0} & \cdots & a_{n,m} \end{pmatrix} \quad [11]$$

$$\|A\| = \sqrt{\sum_{i=0, j=0}^{i=n, j=m} a_{i,j}^2} \quad [12]$$

4.1.2 Monte Carlo methods

Monte Carlo methods are efficient for propagating and estimating models uncertainties accurately. The main problem in such method is computing time. This method will be considered as reference for comparison with the new method we developed. Furthermore, Monte-Carlo method will provide accurate results on each acquisition and process steps and will help to estimate how performances will be increased.

4.1.3 Interval arithmetic method

Interval arithmetic methods have been initially developed due to rounding errors of floating values in computing calculation. The principle is to describe a scalar value with an interval. This help to consider not finite floating values as a duo of floating scalars with specific rounding policies. For example, $\pi \in [3.14; 3.15]$.

This description of values will change arithmetic rules. For example, mathematical product becomes:

$$[-5; -4.5] * [-0.5; 2] = [-10; 2.5]$$

With this arithmetic, we developed a method for propagating uncertainties as boundaries of a noisy system. We will compare this method with Monte-Carlo uncertainties estimations method. We choose, as an example case, the 3D camera projection Matrix (pinhole model).

4.2 3D Camera calibrations

The 3D camera output data is a duet of frames, a RGB one and a depth map. Each of them can be described as pinholes. Then, pixels 3D back-projections in volume are considered in figure (13)

$$z \begin{pmatrix} u \\ v \\ 1 \end{pmatrix} = \begin{pmatrix} f_x & 0 & c_x \\ 0 & f_y & c_y \\ 0 & 0 & 1 \end{pmatrix} \begin{pmatrix} x \\ y \\ z \end{pmatrix} \quad [13]$$

z : Depth at pixel (u,v)

u, v : Coordinates of the considered pixel

f_x : Focal length along x

f_y : Focal length along y

c_x, c_y : Lens centering on the optical axis

x, y, z : Projected point coordinates in volume.

Values of interest in this models are (x,y,z) coordinates of the projected pixel. These coordinates, depending on features detection, will be processed in the VSLAM algorithm.

So as to provide interpretable results, the pinhole must be calibrated, and the calibration process will give interpretable back-projection uncertainties on (x,y) coordinates. Uncertainty on z coordinate will be estimated in function of the depth, material and radioactivity level. Indeed, depth map is computed with

active stereoscopy, which involves infrared coded grids projection and interpretations, which can be sensitive to external interferences.

4.2.1 Uncertainties estimations on camera calibration coefficients

The calibration of the camera consists in minimizing the pinhole projection matrix elements, using a well-known projection pattern.

The calculation of back-projections errors is performed with a Monte-Carlo random selection of calibration values c_x, c_y, f_x, f_y on a hand, and then, these back-projection errors are compared with intervals estimations. Deviations estimations methods are described with equation 14 and 15.

$$\begin{pmatrix} du + u \\ dv + v \\ 1 \end{pmatrix} = \begin{pmatrix} df_x + f_x & 0 & dc_x + c_x \\ 0 & df_y + f_y & dc_y + c_y \\ 0 & 0 & 1 \end{pmatrix} \begin{pmatrix} x \\ y \\ 1 \end{pmatrix} \quad [14]$$

$$\begin{pmatrix} du + u \\ dv + v \\ 1 \end{pmatrix} = \begin{pmatrix} f_x & 0 & c_x \\ 0 & f_y & c_y \\ 0 & 0 & 1 \end{pmatrix} \begin{pmatrix} dx + x \\ dy + y \\ 1 \end{pmatrix} \quad [15]$$

4.2.2 Monte-Carlo estimation:

This method gives exhaustive results on the camera response, but it takes around 2 minutes to be computed for each frame, which is not suitable with real-time computations.

The Figure 20 shows results of Monte-Carlo simulation varying the pinhole projection matrix elements; each matrix element could vary from -10 to +10%. $1e+6$ random selections have been performed. The resulting error due to the lenses system will not cause a larger deviation than 80 pixels on the photographic sensor.

Figure 20: Monte-Carlo estimation of pinhole model uncertainties generation

The second diagram (Figure 21) shows the error amplification by the projection matrix. In this specific case, it doesn't have physical sense because it would represent the variation of a vertex coordinates as a function of pixel coordinate variation, which has no physical sense.

The pinhole model is linear, consequently, variation of output variation norms are distributed along a straight line.

Figure 21: Linear system error amplification by Monte-Carlo methods

The last diagram (Figure 22) combines errors generated and amplified by the pinhole projection matrix. And this error will be considered as input error by the next processing block of the system. (for each value of $\|dT\|$, $\frac{\|dT\|}{\|T\|} < 0.1$)

Figure 22: Global uncertainties generated by the pinhole model

4.2.3 Intervals estimation.

Provided results are less exhaustive than with Monte-Carlo methods, nevertheless, these results are bounding phase space provided by Monte-Carlo method. Furthermore, executing time is around 5ms per frame, which is compliant with real-time analysis and processing.

The figures 23-24-25 show comparisons between uncertainties computed by Monte-Carlo and by intervals. This graphical representation represents the bounding of Monte-Carlo computed values by interval arithmetic method. Interval arithmetic results have been added to Monte-Carlo charts in order to figure both methods results (interval arithmetic results have been encircled to remain visible).

The simulation has been performed considering exactly the same matrix element variations. Indeed, matrix element have been defined as intervals (equation 16)

$$\begin{pmatrix} a_{0,0} & \cdots & a_{0,j} \\ \vdots & \ddots & \vdots \\ a_{i,0} & \cdots & a_{i,j} \end{pmatrix} \quad [16]$$

$X = 0.1 \cdot a_{i,j}$

Figure 23: Comparison between Monte-Carlo and Intervals for estimating uncertainties of pinhole model

Results in figure 23, show a good concordance of both methods, intervals arithmetic provides limits of Monte-Carlo method for intrinsic uncertainties generation.

Concerning the amplification of input system uncertainties, the input vector will be defined as a vector of intervals (equation 17)

$$\begin{pmatrix} x \\ y \\ z \end{pmatrix} \rightarrow \begin{pmatrix} [x - dx, x + dx] \\ [y - dy, y + dy] \\ [z - dz, z + dz] \end{pmatrix} \quad [17]$$

Depending on this definition of the input vector, intervals of the output vector will be estimated, as figuring on figure 24.

In this case, intervals also provide bounds of Monte-Carlo simulation.

Figure 24: Comparison between Monte-Carlo and Intervals for estimating uncertainties Amplification by the pinhole model

Finally, by merging the system extrinsic and intrinsic parameters, a global estimation of generated uncertainties can also be provided with intervals techniques, by bounding Monte-Carlo values (Figure 25).

Figure 25: Comparison between Monte-Carlo and Intervals method for propagating the global uncertainties of the model

4.2.4 Performances benchmark

In this case, both methods can provide clear uncertainties results about input data uncertainties amplification and intrinsic uncertainties generation.

These methods can have different use cases depending on each method pros and cons.

The Monte-Carlo method will describe accurately the different systems, but interval arithmetic method can provide pertinent accuracy indices on each acquisition, in real-time or near real time. Indeed, Monte-Carlo algorithm runs in around two minutes, and interval arithmetic one runs in almost 5ms in the same study case.

4.3 Radiological measurement

The second kind of algorithms input data are nuclear probes outcoming ones.

4.3.1 Dose rate measurements

Dose rate measurements uncertainties are linked to counting errors. Equations [18-19-20] describe the global dose rate counting error.

Count to dose rate pre-processing:

$$\dot{D} = \frac{C_{pm} \cdot H}{(1 - C_{ps} \cdot \tau) \cdot S_d} \quad [18]$$

With:

$$C_{pm} = \frac{60 \cdot C}{t} \quad [19]$$

And Relative uncertainty is given by:

$$u = \frac{k \cdot \sqrt{\frac{N}{t}}}{N} \quad [20]$$

$\dot{D}$: Dose rate (mGy.h⁻¹)

C_{pm} : Count per minute

H : Conversion factor mR.h⁻¹ to mGy.h⁻¹

C_{ps} : Count per second

τ : Detector's dead time constant (s)

S_d : Detector sensibility coefficient (Cpm.mR.h⁻¹)

t : Acquisition time (s)

C : Count during the acquisition time t in seconds

N : Result of counting

u : Relative uncertainty (%)

4.3.2 Spectrum measurements

Gamma spectrometry also depends on counting uncertainties. In this case, counting uncertainties are considered for each spectrometry channel. Spectrometry

uncertainties also depend on energy/efficiency calibration quality and acquisition parameters.

4.4 SLAM method uncertainties

During SLAM acquisitions, each pose computed by odometry and re-estimated following to loop and closure algorithm is associated to a variance, due to statistical way of calculating spatial transforms which gives a confidence index on each pose computation. Concerning the 3D reconstruction, uncertainty will combine poses computations and 3D projection uncertainties.

4.5 Ongoing work

Current work concerns the estimation of each building-block uncertainties generation and amplification, such as depth map variations as a function of the environment conditions, spatial transforms variance due to descriptors variations, numerical applications of back-projection or geostatistical interpolation. Radioactive sources localization uncertainties generation and propagation will also be estimated in order to provide a complete method for estimating uncertainties and errors in such kind of system that combines acquisition of physical measurements and automatic processing in near real-time.

Also, a full benchmark of the system is performed in order to correlate its results with real-time uncertainties estimations. Each building-block will be compared to well-known references systems. For example, in order to compare 3D reconstructions, we will use a Faro scanner as reference, and concerning trajectory computation, Vicon™ camera system will provide reference of spatial motions of the device.

5 Conclusions

The new presented method for 3D Indoor / Real-time Topographical and Radiological Mapping (ITRM), with Visual Simultaneous Localization And Mapping (VSLAM) has been developed to perform near real time acquisitions and post processing for radiological characterization of premises. Such method allows optimizations of operational time, personnel dose and waste minimization. One of the major challenges consists in optimizing the mobile experimental apparatus in order to satisfy the desired performances, by generating optimized programming code, selecting high performance computer units and measuring instrument. Such an optimization needs also a careful study of uncertainties introduced by the used instrumentation and developed algorithms. Indeed, physical measurement must be provided with associated uncertainty, in order to estimate its pertinence. Also, this uncertainties study method will finally enable performing a sensibility analysis of the whole system. Consequently, it will help to define the building blocks to improve and increase the system's performances.

Finally, this new approach that we developed and applied for radiological measurements within the nuclear

field could be of interest in other domains by adapting the sensors for the required measurements (Chemical, environmental...).

This ongoing work is funded by ANRT (Agence Nationale de la Recherche et des Technologies) under a CIFRE contract (number 2013/1542) between AREVA/STMI and CNRS.

References

1. M. Morichi, H. Toubon, R. Venkataraman, J. Beaujoin, Ph. Dubart, "Nuclear measurement technologies & solutions implemented during nuclear accident at Fukushima" in Proceedings of the IEEE/Advancements in Nuclear Instrumentation Measurement and their Applications (ANIMMA) international conference, 2013
2. T. Whelan, H. Johannsson, M. Kaess, J.-J. Leonard, J. McDonald, "Robust real-time visual odometry for dense RGB-D mapping, in proceedings of the IEEE International conference on robotics and Automation (ICRA), 2013, pp. 5724-5731.
3. Ph. Dubart, M. Morichi, "3D topographic and radiological modeling of an environment", STMI International Patent Application WO2015024694 published Feb. 26, 2015
4. F. Hautot, Ph. Dubart, R. Abou-Khalil, M. Morichi, "Novel real-time 3D radiological mapping solution for ALARA maximization" IEEE/Advancements in Nuclear Instrumentation Measurement and their Applications (ANIMMA) international conference, 2015 Lisbon
5. C. Liang-Chia, T. Nguyen Van, S. Hung-Fa, L. and Hsien-I, "In-situ clouds-powered 3-D radiation detection and localization using novel color-depth-radiation (CDR) mapping". In "advanced robotics", vol. 28, no. 12, pp. 841-857, 2014
6. M. Labbé and F. Michaud, "Online Global Loop Closure Detection for Large-Scale Multi-Session Graph-Based SLAM", in Proceedings of the IEEE/RSJ International Conference on Intelligent Robots and Systems, 2014
7. M. Labbé and F. Michaud, "Appearance-Based Loop Closure Detection for Online Large-Scale and Long-Term Operation," in IEEE Transactions on Robotics, vol. 29, no. 3, pp. 734-745, 2013.
8. M. Labbé and F. Michaud, "Memory management for real-time appearance-based loop closure detection," in Proceedings of the IEEE/RSJ International Conference on Intelligent Robots and Systems, 2011, pp. 1271-1276.
9. F. Panza, « Développement de la spectrométrie gamma in situ pour la cartographie de site ». thèse de doctorat. Université de Strasbourg, 2012.